



Proposed Kingspan Clearwater 6 person Treatment plant with sampling chamber to 20q/m soakaway installed as per SEPA requirements. Tank capable of a mean BOD concentration of no more than 20mg/l and a mean Ammonia concentration of no more than 5mg/l. Tank to be a min. 5m from buildings and boundary. Tank to serve proposed new dwelling subject to future warrant. Supplier of tank to provide certificate of conformity to these standards.